SOUTH DELHI MUNICIPAL CORPORATIO
PUBLIC HEALTH DEPARTMENT, WEST ZONE
Vishal Enclave, Rajouri Garden, New Delhi - 110027

स्वच्छ भारत
एक कदम स्वच्छता की ओर

No. D-1214/HD/W2

Dated: 15/5/18

Health Certificate

1. Name of the school OXFORD Senior Secondary School
2. School address E-Block, Vikas Puri, New Delhi - 110018
3. No of shifts One Timings 7.40 to 1.30 PM.
4. No. of students :-Boys 1995 Girls 1553 Total 3548
5. No. of staff:- Gents 29 Ladies 148 Total 177

Accommodation provided for classroom as under:-

Floor area in the classroom is sufficient / insufficient Sufficient
Classes are well lighted / ill lighted Well Lighted
Classrooms are well ventilated / ill ventilated Well Ventilated
Classes are kept / not kept neat and clean Neat & clean
Building / classrooms require / do not require white wash etc. Not require
Drinking water is wholesome / not wholesome Wholesome
Latrine arrangement is sanitary / insanitary Sanitary from Health Point of view.

No . of toilets seats for students

One Latrine-cum-urinal is required for 25 female students, so total is Sufficient
One Latrine for 40 male students is required, so total is Sufficient
Separate toilet arrangement for staff yes/ no yes exist from staff
The overall facilities good / adequate / inadequate V. Good from Health Point of view.

If Building Department or any other Govt agency takes action against u/a construction any dispute, then the Health Certificate will be stand cancelled revoked without any further intimation in this regard.

Dy. Health Officer
Dr SAURABH MISHRA
MBBS, M.D
Dy Health Officer
West Zone